



Product Service

CERTIFICATE

No. Z2 15 05 83137 042

Holder of Certificate: Jiangyin Hareon Power Co., Ltd

No. 178 Huanzhen North Road,
 Huangtang Industrial Zone,
 Xuxiake Town,
 214407 Jiangyin, Jiangsu
 PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:****Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
 Poly-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061404208-00

Valid until: 2020-05-03



Date, 2015-05-04

(Zhulin Zhang)

Page 1 of 2



Product Service

CERTIFICATE**No. Z2 15 05 83137 042****Model(s):****HR-240P-18/Bbd, HR-245P-18/Bbd, HR-250P-18/Bbd,
HR-255P-18/Bbd, HR-260P-18/Bbd, HR-265P-18/Bbd,
HR-270P-18/Bbd, HR-275P-18/Bbd;****Parameters:**

Rated Output Power at STC:	240W, 245W, 250W, 255W, 260W, 265W, 270W, 275W;
Construction:	Frameless, double glass with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No.10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Application Class:	Class A
Maximum System Voltage:	1000 V DC
Fire Safety Class:	Class C

**Tested
according to:****IEC 61215(ed.2)
EN 61215:2005
IEC 61730-1(ed.1);am1;am2
EN 61730-1:2007/A2:2013
IEC 61730-2(ed.1);am1
EN 61730-2:2007/A1:2012****Production
Facility(ies):****83137, 83138, 83145**