



Product Service

CERTIFICATE


No. Z2 15 05 83137 044

Holder of Certificate: **Jiangyin Hareon Power Co., Ltd**

No. 178 Huanzhen North Road,
Huangtang Industrial Zone,
Xuxiake Town,
214407 Jiangyin, Jiangsu
PEOPLE'S REPUBLIC OF CHINA



Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Poly-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061404210-00

Valid until: 2020-05-20



Date, 2015-05-26

(Zhulin Zhang)

Page 1 of 2



Product Service

CERTIFICATE

No. Z2 15 05 83137 044

Model(s):

HR-240P-18/Bbd, HR-245P-18/Bbd, HR-250P-18/Bbd,
HR-255P-18/Bbd, HR-260P-18/Bbd, HR-265P-18/Bbd,
HR-270P-18/Bbd, HR-275P-18/Bbd;

Parameters:

Rated Output Power
at STC: 240W, 245W, 250W,
255W, 260W, 265W,
270W, 275W;

Construction: Frameless, double glass with
Junction box, Cable and Connectors.

Application Class: Class A
Maximum System Voltage: 1000 V DC
Fire Safety Class: Class C
Severity of salt
mist test: Level 6

Tested according to:

IEC 61215(ed.2)
IEC 61730-1(ed.1);am1;am2
IEC 61730-2(ed.1);am1
IEC 61701:2011

Production Facility(ies):

83138, 83137, 83145